

U

PENDIN

## QUALITY ELECTRONIC DESIGN



# W.DEM-IT.COM

## **CURRENT TRANSFORMER** AC/DC TRMS - RS485 MODBUS

QI-50-V-485


CE

QI-50-V-485


CURRENT TRANSFORMER AC/DC TRMS - R5485 MODBUS

	POWER SUPP	PLY 1230Vdc, Protection against							
	polarity reversa	l and overtemperature.							
	ABSORPTION	Max 20mA							
	PROTECTION	I INDEX IP20							
	ACCURACY	0,5% F.S.							
	RESOLUTION	12 bit							
	TEMPERATUR	RE COEFFICIENT < 200 ppm/°C							
	WORKING TE	EMPERATURE -15+65°C							
	STORAGE TE	MPERATURE -40°C +85°C							
	RESPONSE T	IME 1000 ms on analog output, 30ms							
	on serial output	t							
	TYPE OF MEA	SURE TRMS (monopolar)							
_	RANGE 50	Arms o 25 Arms dip-switch setting,							
	•	DC o +/-25A DC), RS485 customize							
	setting								
		10V and RS485							
-	BAND WIDTH	AT -3dB DC or 202000 Hz							
	ISOLATION	3 kV on bare wire							
	OVERLOAD	2000A pulse, 300A continuos							
	CREST FACTO	DR 2							
6	HYSTERESIS	0,15% f.s.							
	HUMIDITY	1090% not condensing							
	ALTITUDE	Up to 2000 m s.l.m.							
	WEIGHT 72 g.								
	FILLING Epoxy Resins								
	BOX MATERIA	AL PBT, grey							
//	MOUNTING	Screw predisposition for vertical/							
		nting, DIN rail clips (included) for							
	vertical/horizon								
		Removable terminals 3,5mm, 5 poles							
	DIP-SWITCH	• •							
1	LED N°1 yel	llow, Power on fixed, data							
	STANDARDS	CE EN61000-6-4/2006 + A1 2011; 2005 ; EN61010-1/2010							
/	2.101000 0 2/20								


### DIMENSIONS 46,1x 63x 26,4 mm (terminal excluded)



The QI-50-V-485 is a AC/DC current transformer, galvanically isolated from the measuring circuit. The device is in the function and appearance is very similar to a standard active TA, however, able to measure the DC component and AC TRMS. The transformer is equipped with RS485 Modbus serial output and an analog output 0-10V. Through the serial port can be configured freely span and zero and assign the Modbus address.







ISOLATION AND CONNECTIONS

← 5 Power ← 4 B-

It's possible to connect via serial RS485 to the QI-50-V-48 through a converter USB/232-485 for setting the parameters of zero and span and configuration of the Modbus addresses directly from your system of supervision, or using the free FACILE QI-50-V-485 software. You can download our software on www.qeed.it






QUALITY ELECTRONIC DESIGN





o the

## CURRENT TRANSFORMER AC/DC TRMS - RS485 MODBUS



Via the serial link RS485-USB you can connect to the QI-50-V-485 via the interface program FACILE QI-50-V-485. Using this software, free download from www.qeed.it, allows you to configure the processor by setting the START and STOP input and output (see diagram), you can set the Modbus address of the PC to which the query transformer and decide whether to make monopolar (only positive or negative values) or bipolar (see diagram). If you are using bipolar function on AC current, the value read will be 0 A (5 V) because you are reading the average value.

**QI-50-V-485** 

DIN rail mounting instructions:

By means of dip-switch can configure the QI-50-V-485 to set the scale to 25 or 50A, the function monopolar (TRMS) or bipolar (mean value), the Modbus address (see register map below) up to a maximum of 15 addresses.

**MOUNTING:** The current transformer QI can be mounted in any position (see photo below), horizontal or vertical mounting, horizontal or vertical through the two hooks for DIN rail included in the box.

CAUTION: Magnetic fields of high intensity can vary the values measured by the transformer. Avoid installation near permanent magnets, electromagnets or iron masses that induce strong changes in the magnetic field. If any irregularity recommend reorient or move the transformer in the area most appropriate.

#### REMARKS:

- Modbus connections: A+ and B- as per Modbus RTU standards;
- Modbus Register reference: with reference to the logical address, for ex. 40010, corresponds to physical address n°9 as per Modbus RTU standard;
- Dip Switch Settings: the setting is not enabled if the first fourth dip-switches are set to 0000, the rest of dip-switch are disabled. All settings coming from EEPROM.
  - Modbus functions supported: 3 (Read multiple registers, max 4), 6 (Write single).



#### Modbus register table:

Register Name	Comment	Register Type	R/W	DEFAULT	Range	Modbus	
				Value		Address	
machine_ID	ID Machine	Unsigned 16 bits	R	4		40001	
FW_Version	Firmware Release	Unsigned 16 bits	R			40002	
addr	Modbus Address	Unsigned 16 bits	R/W	1	1250	40003	
Delay	Answer Delay	Unsigned 16 bits	R/W	1	11000	40004	
Baudrate	Baudrate 0=1200 / 1= 2400 2= 4800 / 3= 9600 4= 19200 / 5= 38400 6= 57600 / 7= 115200	Unsigned 16 bits	R/W	1	07	40005	
parity	Type of parity 0= 8,N,1 1= 8, O, 1(ODD) 2= 8, E, 1 (EVEN)	Unsigned 16 bits	R/W	0	02	40006	
In_start	Start Input (A)	Floating 32 bits	R/W	0		40007 (L 40008 (H	
In_stop	Stop Input (A)	Floating 32 bits	R/W	50		40009 (L 40010 (H	
Out_start_V	Start Output (mV)	Unsigned 16 bits	R/W	0	010000	40011	
Out_stop_V	Stop Output (mV)	Unsigned 16 bits	R/W	10000	010000	40012	
filt1	n° of samples for mobile average (1= 100ms)	Unsigned 16 bits	R/W	1	132	40013	
filt	Second level filter for ripple problems on AC measurement	Unsigned 16 bits	R/W	4096	1000 20000	40014	
RMS_A	RMS Current Value (A)	Floating 32 bits	R			40037 (L 40038 (H	
status	Status Register bit 0 =1 : Error flash settings bit 1=1:Error flash calibration bit 2=1 : Over Range bit 3=1 : Under Range	Unsigned 16 bits	R			40048	
RMS_100	RMS Value of Current (A x 100)	Signed 16 bits	R			40050	
RMS_sw	RMS Current Value (A) swapped	Floating 32 bits	R			40051 (H 40052 (L	
Ah	Ah counting (resettable)	Floating 32 bits	R/W			40053 (L 40054 (H	
A_MAX	Max current value/100 (resettable)	Signed 16 bits	R/W			40055	
A_min	min current value/100 (resettable)	Signed 16bits	R/W			40056	

Dip-switch table:

DESCRIPTION	1	2	3	4	5			
All settings from EEPROM	0	0	0	0				11
ADD= 1	0	0	0	1				
ADD= 2	0	0	1	0				
ADD=15	1	1	1	1				
2400 BAUDRATE					0	0		
9600 BAUDRATE					0	1		
38400 BAUDRATE					1	0		
57800 BAUDRATE				7		1		
MONOPOLAR (TRMS)							0	
BIPOLAR (MEAN VALUE)							1	
50 A								0
25 A				0				1

#### **Dip-Switch Settings**

**Example** : if you want to set the measure range from 0...50 A to 0... 25A, please, put ON the dip-switch n°8 and put ON also one of the first four dip-switch (if you don't do that it continue to take the EEPROM setting).

If you want to modify from Monopolar (default) to Bipolar function by dip-switch, please, put ON the dip n°7 and put ON also one of the first dip-switch (if you don't do that it continue to take the EEPROM setting).

Any changes made by dip-switch required to switch off the power supply. It's a safety condition in order to prevent any manumission on the device.

> This document is the property of DEM spa. Duplication or reproduction is prohibited. The contents of this document correspond to the products and technologies described. This information may be amended or supplemented by technical and commercial requirements

